ALS Group USA, Corp.
10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:
Drinking Water System Components – Health Effects

Company:
Alchatek, LLC
4508 Bibb Blvd
Suite B-5
Tucker, GA 30084, United States

Plant Location:
Tucker, GA, United States

Standards:
NSF/ANSI/CAN 61 - 2024
NSF/ANSI/CAN 372 - 2024

Certificate:
Issued Date: 08/27/2025

Material/Product:
Spetec PUR F400- Polyurethane injection resin

Contact Temperature:
23 ± 2°C

Models:
Spetec PUR F400

Maximum surface area in contact with water shall not exceed more than 1% of the total surface area.

Material Characteristics:

Minimum tank size (gallons): 40000

Maximum tank surface area/volume ratio (sq in/L): 1.7

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hrs at 23 Â± 2 Â°C

Final cure time: 24 hrs at 23 Â± 2 Â°C

Mix ratio: 18:1:1

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum surface area in contact with water shall not exceed more than 1% of the total surface area.